

## Retail Firework Stand Check List

**Information listed below is based on Arkansas Code Annotated, NFPA 1124, 2006 Edition, and the 2012 Arkansas Fire Prevention Code, Volume 1.**

Compliance Yes No	Not Applicable	
<input type="checkbox"/> <input type="checkbox"/>	<input type="checkbox"/>	A retail permit for the current selling period is required <u>to be displayed</u> in all retail stands with the correct information included for that specific stand.
<input type="checkbox"/> <input type="checkbox"/>	<input type="checkbox"/>	Signs shall be posted with the words, “ <b>FIREWORKS – NO SMOKING</b> ” in letters not less than four inches (4”) high at each entrance to the retail sales area (20-22-710(b)).  At least one sign that reads as follows, “ <b>FIREWORKS—NO SMOKING</b> ” in letters at least 2 inch high on a contrasting background, shall be conspicuously posted at each entrance or within 10 feet of every aisle directly serving the Consumer Fireworks Retail Sales Stand (CFRS) area in a store(NFPA 1124, 2006 Edition, Section 7.3.11.2).
<input type="checkbox"/> <input type="checkbox"/>	<input type="checkbox"/>	All licensees shall <u>have a fire extinguisher of a type approved by the Director of the Department of Arkansas State Police</u> in an area readily accessible to any point of storage or sale of fireworks. In lieu of such an extinguisher, retailers may maintain a common type of water hose, charged and connected to a water system, which is readily available to any area where fireworks are stored or sold (20-22-710(e)).
<input type="checkbox"/> <input type="checkbox"/>	<input type="checkbox"/>	Permissible items of fireworks, defined in § <b>20-22-708</b> , may be sold at retail to residents of the State of Arkansas and used within the State of Arkansas from June 20 through July 10 and December 10 through January 5 of each year only (20-22-711).
<input type="checkbox"/> <input type="checkbox"/>	<input type="checkbox"/>	It shall be unlawful to offer for retail sale or to sell any fireworks to children twelve (12) years of age or to any person know to be intoxicated or irresponsible (20-22-712).
<input type="checkbox"/> <input type="checkbox"/>	<input type="checkbox"/>	It shall be unlawful to explode or ignite fireworks within six hundred feet (600’) of any church, hospital, asylum, public school, or within two hundred feet (200’) of where fireworks are stored, sold, or offered for sale (20-22-713(a)).
<input type="checkbox"/> <input type="checkbox"/>	<input type="checkbox"/>	No person shall construct a retail display nor offer for sale explosives, explosive materials, or fireworks upon highways, sidewalks, public property, or in Group A or E occupancies (5601.2.2)
<input type="checkbox"/> <input type="checkbox"/>	<input type="checkbox"/>	Consumer Fireworks Retail Sales Stand (CFRS). A temporary or permanent building or structure that has a floor area not greater than 800 sq. ft., other than tents, canopies, or membrane structures, that is used primarily for the retail display and sale of consumer fireworks to the public (NFPA 1124, 2006 Edition, Section 3.3.19).  Stands can include, but are not limited to, small buildings, plywood or sheet metal structures, manufactured buildings, semitrailers, trailers, shipping containers, or similar structures or facilities (Section A.3.3.19).
<input type="checkbox"/> <input type="checkbox"/>	<input type="checkbox"/>	Every Consumer Fireworks Retail Sales Stand (CFRS) existing and new stands and tents, and temporary CFRS facilities shall not be located within 50 feet of motor vehicle fuel-dispensing station dispensers (NFPA 1124, 2006 Edition, Section 7.3.12.2).
<input type="checkbox"/> <input type="checkbox"/>	<input type="checkbox"/>	Consumer Fireworks Retail Sales Stand (CFRS) areas and storage area shall not be located within 300 feet of any aboveground bulk storage or bulk dispensing area of the following: Flammable or combustible liquid, Flammable gas, or Flammable liquefied gas (NFPA 1124, 2006 Edition, Section 7.3.12.6). <i>(Only applies to Bulk Dispensing and Bulk Storage)</i>
<input type="checkbox"/> <input type="checkbox"/>	<input type="checkbox"/>	Exits provided for the retail sales of tents, membrane structures, canopies, and permanent Consumer Fireworks Retail Sales Stand (CFRS) facilities, including Class C stores, shall be located so that the maximum egress travel distance, measured from the most remote point to an exit along natural and unobstructed path of egress travel, does not exceed 75 feet (NFPA 1124, 2006 Edition, Section 7.3.14.2).
<input type="checkbox"/> <input type="checkbox"/>	<input type="checkbox"/>	Aisles shall terminate at an exit, another aisle, or a cross-aisle (NFPA 1124, 2006 Edition, Section 7.3.14.3.2.3).
<input type="checkbox"/> <input type="checkbox"/>	<input type="checkbox"/>	Dead-end aisles shall be prohibited (NFPA 1124, 2006 Edition, Section 7.3.14.3.2.4).

## Retail Firework Stand Check List

**Information listed below is based on Arkansas Code Annotated, NFPA 1124, 2006 Edition, and the 2012 Arkansas Fire Prevention Code, Volume 1.**

Compliance Yes No	Not Applicable	
<input type="checkbox"/> <input type="checkbox"/>	<input type="checkbox"/>	To provide visual access of the retail sales area by the employees and customers, partitions, counters, shelving, cases, and similar dividers shall not exceed 6 feet height above the floor surface inside the perimeter of the retail sales area (NFPA 1124, 2006 Edition, Section 7.3.15.2).
<input type="checkbox"/> <input type="checkbox"/>	<input type="checkbox"/>	Merchandise on display or located on shelves or counters or other fixtures shall not be displayed to height greater than 6 feet above the floor surface within the Consumer Fireworks Retail Sales Stand (CFRS) area (NFPA 1124, 2006 Edition, Section 7.3.15.2.1).
<input type="checkbox"/> <input type="checkbox"/>	<input type="checkbox"/>	Where located along the perimeter or consumer fireworks retail sales area, the maximum height of sales displays shall be limited to 12 feet (NFPA 1124, 2006 Edition, Section 7.3.15.3.3).
<input type="checkbox"/> <input type="checkbox"/>	<input type="checkbox"/>	Smoking shall not be permitted inside or within 50 feet of Consumer Fireworks Retail Sales Stand (CFRS) area (NFPA 1124, 2006 Edition, Section 7.3.11.1).
<input type="checkbox"/> <input type="checkbox"/>	<input type="checkbox"/>	20-22-713. Place of explosion or ignition.  (a) It shall be unlawful to explode or ignite fireworks within six hundred feet (600') of any church, hospital, asylum, public school, or within two hundred feet (200') of where fireworks are stored, sold, or offered for sale.  (b) No person shall ignite or discharge any permissible articles of fireworks within, or throw the fireworks from, a motor vehicle while therein, nor shall any person place or throw any ignited article of fireworks into or at a motor vehicle or at or near any person or group of people
<input type="checkbox"/> <input type="checkbox"/>	<input type="checkbox"/>	Consumer Fireworks Retail Sales Stand (CFRS) areas and storage rooms shall be kept free of accumulations of debris and rubbish (NFPA 1124, 2006 Edition, Section 7.3.21.1).
<input type="checkbox"/> <input type="checkbox"/>	<input type="checkbox"/>	Any loose pyrotechnic composition shall be removed immediately (NFPA 1124, 2006 Edition, Section 7.3.21.2).
<input type="checkbox"/> <input type="checkbox"/>	<input type="checkbox"/>	Vacuum cleaners or other mechanical cleaning devices shall not be used (NFPA 1124, 2006 Edition, Section 7.3.21.3).
<input type="checkbox"/> <input type="checkbox"/>	<input type="checkbox"/>	Brooms, brushes, and dustpans used to sweep up any loose powder or dust shall be made of non-sparking materials (NFPA 1124, 2006 Edition, Section 7.3.21.4).
<input type="checkbox"/> <input type="checkbox"/>	<input type="checkbox"/>	Consumer fireworks devices that are damaged shall be removed and not offered for sale (NFPA 1124, 2006 Edition, Section 7.3.21.5).
<input type="checkbox"/> <input type="checkbox"/>	<input type="checkbox"/>	Separation between tents and structures shall be at least 20 feet, and vehicle parking shall be at least 10 feet from tents (NFPA 1124, 2006 Edition, Table 7.4.7.2).
<input type="checkbox"/> <input type="checkbox"/>	<input type="checkbox"/>	Smoking material, matches, lighters, or open flame devices shall not be allowed within 50 feet of any area where fireworks or other pyrotechnic material are present (NFPA 1124, 2006 Edition, Section 6.11.5.1.1). <i>(Only applies to manufacturing and distribution facilities)</i>
<input type="checkbox"/> <input type="checkbox"/>	<input type="checkbox"/>	Open flame cooking equipment of any type shall not be allowed within 50 feet of tents, canopies, or membrane structures used for sale of consumer fireworks (NFPA 1124, 2006 Edition, Section 7.4.9.3.2).
<input type="checkbox"/> <input type="checkbox"/>	<input type="checkbox"/>	Portable generators supplying power to Consumer Fireworks Retail Sales Stand (CFRS) shall use only Class II or Class III fuel and be limited to no more than 5 gallons, shall be at least 20 feet from CFRS, and fuel storage shall be 50 feet from CFRS (NFPA 1124, 2006 Edition, Section 7.3.18.1).

## Retail Firework Stand Check List

Information listed below is based on Arkansas Code Annotated, NFPA 1124, 2006 Edition, and the 2012 Arkansas Fire Prevention Code, Volume 1.

Compliance Yes No	Not Applicable	
<input type="checkbox"/> <input type="checkbox"/>	<input type="checkbox"/>	Portable generators shall be permitted to use Class I flammable liquids as fuel, provided the quantity of such fuel is limited to 2 gallons, shall be at least 20 feet from the Consumer Fireworks Retail Sales Stand (CFRS), and fuel storage shall be 50 feet from the CFRS (NFPA 1124, 2006 Edition, Section 7.3.18.2). <i>(Temporary Facilities)</i>
<input type="checkbox"/> <input type="checkbox"/>	<input type="checkbox"/>	Battery powered equipment, electrical equipment, and electrical cords that are used in conjunction with the Consumer Fireworks Retail Sales Stand (CFRS) facility area shall be listed and shall be used in accordance with their listing (NFPA 1124, 2006 Edition, Section 7.4.9.1). <i>(Temporary Facilities)</i>
<input type="checkbox"/> <input type="checkbox"/>	<input type="checkbox"/>	Temporary wiring installed in temporary structure, including tents and canopies, shall comply with Article 305 of NFPA 70, National Electrical Code (NFPA 1124, 2006 Edition, Section 7.4.9.1.1).
<input type="checkbox"/> <input type="checkbox"/>	<input type="checkbox"/>	Any portion of an exterior wall of a building, sidewall of a tent, or other defined perimeter of a Consumer Fireworks Retail Sales Stand (CFRS) facility or store shall be accessible within 150 feet of a public way or an approved fire apparatus access (NFPA 1124, 2006 Edition, Section 7.3.4).
<input type="checkbox"/> <input type="checkbox"/>	<input type="checkbox"/>	No person shall construct a retail display nor offer for sale explosives, explosive material or fireworks upon highways, sidewalks, public property or in a Group A or E occupancies (2012 Arkansas Fire Prevention Code, Vol.1, Section 5601.2.2).
<input type="checkbox"/> <input type="checkbox"/>	<input type="checkbox"/>	The fire code official is authorized to limit the quantity of explosives, explosive materials or fireworks permitted at a given location. No person processing a permit for storage of explosives at any place, shall keep or store an amount greater than authorized in such permit. Only the kind of explosive specified in such permit shall be kept or stored (2012 Arkansas Fire Prevention Code, Vol.1, Section 5601.2.3).
<input type="checkbox"/> <input type="checkbox"/>	<input type="checkbox"/>	Sky Lanterns are not allowed for sell or use in the State of Arkansas (20-22-717).